



## LS External Handles FOR MOULDED CASE CIRCUIT BREAKERS



Direct Rotary Handle



Extended Rotary Handle

Part No.	Type	Suitable Models
<b>Direct Rotary Handle</b>		
83111172801	DH2-S	TS100, 160, 250
83111173801	DH3-S	TS400, 630
83111174801	DH4-S	TS800
<b>Extended Rotary Handle</b>		
83111172806	EH2-S	TS100, 160, 250
83111173806	EH3-S	TS400, 630
83111174806	EH4-S	TS800

## LS Manual Motor Starters MOTOR CIRCUIT BREAKERS



### Features

- Adjustable thermal release
- Lockout with Handle
- Large Scale for current setting
- Touch safe terminals



Part No.	Type	Dimensions	Min Rating (A)	Max Rating (A)
<b>32H</b>				
0705000400	MMS-32H-0.63A	W45 x H94 x D100	0.4	0.63
0705000500	MMS-32H-1A	W45 x H94 x D100	0.63	1
0705000600	MMS-32H-1.6A	W45 x H94 x D100	1	1.6
0705000700	MMS-32H-2.5A	W45 x H94 x D100	1.6	2.5
0705000800	MMS-32H-4A	W45 x H94 x D100	2.5	4
0705000900	MMS-32H-6A	W45 x H94 x D100	4	6
0705001100	MMS-32H-10A	W45 x H94 x D100	6	10
0705001300	MMS-32H-17A	W45 x H94 x D100	11	17
0705001200	MMS-32H-13A	W45 x H94 x D100	9	13
0705001400	MMS-32H-22A	W45 x H94 x D100	14	22
0705001500	MMS-32H-32H	W45 x H94 x D100	18	26
0705001600	MMS-32H-32A	W45 x H94 x D100	22	32
<b>63H</b>				
0706001300	MMS-63H-22A	W55 x H140 x D145	14	22
0706001600	MMS-63H-40A	W55 x H140 x D145	28	40
0706001700	MMS-63H-50A	W55 x H140 x D145	34	50
0706001800	MMS-63H-63A	W55 x H140 x D145	45	63

## LS Auxiliary Feedback FOR MANUAL MOTOR STARTERS



Auxiliary Switch Units (Front Mount)



Auxiliary Switch Units (Left Hand Side)

Part No.	Type	Contacts	Mounting Type	Notes
<b>Auxiliary Switch Units (Front Mount)</b>				
83361941001	FX	2 NO	Front Mount	One per unit
83361941002	FX	1 NO / 1NC	Front Mount	One per unit
<b>Auxiliary Switch Units (Left Hand Side)</b>				
83361941004	LX	2 NO	Left Hand Side	
83361941005	LX	1 NO / 1NC	Left Hand Side	
83361941006	LX	2 NC	Left Hand Side	
<b>Alarm Contact Units</b>				
83011941005	LAM - Magnetic Trip Alarm Switch	1 NO / 1NC	Left Hand Side	Set LAM first in case of using LX together
83011941002	LA - Any Trip Alarm Switch	1 NO / 1NC	Left Hand Side	MMS-63 can not accept LX and LA together